

MANUFACTURED HOMES MINIMUM INSPECTION REQUIREMENT

ELECTRICAL SERVICE

- 1. All service conductors must be correctly sized, and in conduit or be in the proper cable approved for outside exposure.
 - a) 100 Amp Service: #4 Copper or #2 Aluminum**
 - b) 200 Amp Service: 2/0 Copper or 4/0 Aluminum****

- 2. Disconnect must be grounded with a #6 AWG copper conductor connected two driven 8 foot rods, 6 feet apart of:
 - a) 1/2 inch copper**
 - b) 5/8 inch iron or steel**
 - c) 3/4 inch galvanized or coated iron or steel pipe****

- 3. Home frame must be grounded in the same manner**

PLUMBING CONNECTION

- 1. No mixing of PVC and ABS unless mechanical couplings are used.**

- 2. Gluing of piping must include using the proper purple primer applied to the pipe before the glue.**

- 3. Pipe must be supported at 4 foot intervals.**

**THESE ARE MINIMUM REQUIREMENTS
TO RECEIVE APPROVAL FOR ELECTRICAL
CONNECTION TO ALL ISSUES MENTIONED ABOVE AND
THEY MUST BE COMPLETED AND INSPECTED.**